

**Fire Sprinkler System
Control Valve**

System #

Address and Street

Fire Sprinkler System Sign Specifications

1. Sign sizes to fit required lettering height and stroke
2. Sign stock shall be .08 gauge, reflectorized aluminum.
3. All lettering shall be white reflective on red reflective background.
4. "Fire Sprinkler System Control Valve" lettering shall be 1 1/2 inches in height with a 1/4 inch paint stroke
5. System # lettering shall be 1 inch in height with a 1/4 inch paint stroke
 - a. Provide System # for multiple systems
6. Address and Street lettering shall be 1 1/2 inches in height with a 1/4 inch paint stroke
7. Sign shall be mounted by the following:
 - a. On a sign post with the bottom of the sign a minimum 5 feet from grade, or
 - b. If the fire sprinkler control valve is installed next to a structure, attached to the structure above the fire sprinkler control valve